DATAFORTH[®]

DSCA39 Current Output Signal Conditioners

Description

Each DSCA39 current output module provides a single channel of analog output. The input signal is buffered, isolated, filtered and converted to a unipolar or bipolar current output. Signal filtering is accomplished with a five-pole filter which provides 100dB per decade of attenuation above 1kHz. An anti-aliasing pole is located on the system side of the isolation barrier, and the other four poles are on the field side. After the initial system-side filtering, the input signal is chopped by a proprietary chopper circuit. Isolation is provided by transformer coupling, again using a proprietary technique to suppress transmission of common mode spikes or surges.

Special output circuits provide protection against accidental connection of power-line voltages up to 240VAC and against transient events as defined by ANSI/IEEE C37.90.1. Protection circuits are also present on the signal input and power input terminals to guard against transient events and power reversal. Signal and power lines are secured to the module using screw terminals which are in pluggable terminal blocks for ease of system assembly and reconfiguration.

The modules have excellent stability over time and do not require recalibration, however, zero and span settings are adjustable up to $\pm 5\%$ to accommodate situations where fine-tuning is desired. The adjustments are made using potentiometers located under the front panel label and are non-interactive for ease of use.

Features

- Accepts High Level Voltage Input
- Provides 4 to 20mA, 0 to 20mA, or -20 to +20mA Output
- ANSI/IEEE C37.90.1 Transient Protection
- 1500Vrms Transformer Isolation
- ±0.03% Accuracy
- ±0.01% Linearity
- Output Protected to 240VAC Continuous
- · True 3-Way Isolation
- · Wide Range of Supply Voltage
- 100dB CMR
- · Easily Mounts on Standard DIN Rail
- C-UL-US Listed
- · CE and ATEX Compliant




Figure 1: DSCA39 Block Diagram

Specifications Typical at T_A=+25°C and +24V supply voltage

Model DSCA39-01, -02, -03, -04 DSCA39-05 DSCA39-07 Output Range 4 to 20mA or 0 to 20mA 0 to 20mA -20mA to +20mA Over Range Capability 10% 5% Output Compliance Voltage (Open Circuit) 22VDC ±15VDC Load Resistance Range 0 to 750Ω 0 to 500Ω **Output Protection** . Continuous 240Vrms max ANSI/IEEE C37.90.1 Transient ±10V or 0V to +10V Input Range 0 to 20mA ±10V Input Resistance Normal $2M\Omega$ <1000 Power Off $2M\Omega$ <100Ω 2MO $65 k\Omega$ Overload Input Protection ±35V max 75mA Continuous ANSI/IEEE C37.90.1 Transient CMV, Output to Input, Output to Power Continuous 1500Vrms max Transient ANSI/IEEE C37.90.1 CMV, Input to Power 50VDC max Continuous CMR (50Hz or 60Hz) 110dB ±0.05% Accuracy⁽¹⁾ ±0.03% Span Nonlinearity ±0.01% Span Adjustability ±5% Zero and Span Stability Zero ±20ppm/°C ±40ppm/°C ±50ppm/°C Span Output Noise, 100kHz Bandwidth 4µArms Bandwidth, -3dB 1kHz NMR 100dB/Decade Above 1kHz Response Time, 90% Span 475µs Power Supply 15 to 30VDC 19 to 29VDC Voltage Current 65mA Sensitivity ±0.0003%/% Protection Reverse Polarity Continuous ANSI/IEEE C37.90.1 Transient Environmental Operating Temp. Range -40°C to +80°C ATEX Group II, Category 3 -20°C to +40°C Storage Temp. Range -40°C to +80°C Relative Humidity 0 to 95% Noncondensing Emissions EN61000-6-4 ISM, Group 1 Class A Radiated, Conducted Immunity EN61000-6-2 ISM, Group 1 RF Performance A ±0.05% Span Error ESD, EFT, Surge, Voltage Dips Performance B * Mechanical Dimensions 2.95" x 0.89" x 4.13" (75mm x 22.5mm x 105mm) (h)(w)(d) DIN EN 50022 -35x7.5 Mounting or -35x15 rail

Ordering Information

Model	Input Range	Output Range
DSCA39-01	0V to +10V	4mA to 20mA
DSCA39-02	-10V to +10V	4mA to 20mA
DSCA39-03	0V to +10V	0mA to 20mA
DSCA39-04	-10V to +10V	0mA to 20mA
DSCA39-05	4mA to 20mA	4mA to 20mA
DSCA39-07	-10V to +10V	-20mA to +20mA

NOTES:

* Same specification as DSCA39-01, -02, -03, -04

(1) Includes nonlinearity, hysteresis and repeatability.

Installation Notes:

1.) This Equipment is Suitable for Use in Class I, Division 2, Groups A, B, C, D, or Non-Hazardous Locations Only.

2.) Warning - Explosion Hazard - Substitution of Components May Impair Suitability for Class I, Division 2.

3.) Warning - Explosion Hazard - Do Not Disconnect Equipment Unless Power Has Been Switched Off or The Area is Known to be Non-Hazardous.